

PFAS 2019 Testing – All Wells
March, 2019 sampling.

Results in Parts Per Trillion (ppt)

PFAS Compound	Length	Well 06	Well 09	Well 14	Well 15	Well 16
Perfluorobutanoic acid (PFBA)	Short	PRESENT	not tested	3.6	2.9	PRESENT
Perfluorobutanesulfonic acid (PFBS)	Short	PRESENT	PRESENT	PRESENT	3.1	PRESENT
Perfluoropentanoic acid (PFPeA)	Short	not detected	not tested	1.9	5.1 - 5.9	PRESENT
Perfluoropentane sulfonic acid (PFPeS)	Short	not detected	not tested	PRESENT	2.7	not detected
Perfluorohexanoic acid (PFHxA)	Short	not detected	PRESENT	2.3	6.1	PRESENT
Perfluoroheptanoic acid (PFHpA)	Short	not detected	ND	PRESENT	2.5	PRESENT
Perfluorohexanesulfonic acid (PFHxS)	Long	PRESENT	1.2	4.8	20 - 21	2.5
Perfluoroheptane sulfonic acid (PFHpS)	Long	not detected	not tested	not detected	PRESENT	not detected
Perfluorooctanoic acid (PFOA)	Long	PRESENT	PRESENT	PRESENT	5.4 - 5.7	PRESENT
Perfluorooctanesulfonic acid (PFOS)	Long	not detected	PRESENT	PRESENT	5.3 - 5.8	PRESENT
Combined PFOA + PFOS		0.8*	0.8*	2.4*	11-12	2.3*

PRESENT: Substance detected at levels too low to accurately quantify

* estimated concentration (ppt)

Well 11 will be re-tested due to lab quality control issues. Preliminary results **do** indicate the presence of low levels of PFAS.